

ARIZONA COURTLINES, INC. SPECIFICATIONS

DC-WDC (ACI MODEL #) DIVIDER CURTAIN - WALK DRAW (CABLE)

CABLE / TROLLEYS / STORAGE UNIT

1/4" Cable shall attach to opposite walls using a minimum of 4 anchors each (anchors shall be supplied by installer). One piece of cable shall span the entire distance from wall to wall. A turnbuckle shall be secured to each wall attachment bracket and to each end of the cable. Turnbuckle shall allow enough travel to tighten cable, so that the cable hangs completely horizontal with full weight of curtain applied. A 1/4" vertical cable shall support the center of the horizontal cable. Trolleys shall be placed a maximum of 2'-0" O/C for the entire length of the curtain. Each Trolley shall be capable of supporting a minimum of 50 pounds (for attachments above 40'-0" a 70 pound (minimum) trolley is required). Curtain shall be suspended from Trolleys by 3/16" S-hooks and 3/16" chains. 3/16" chains shall be used to level the curtain. 6'-0" tall Velcro strips shall be shown to the center of each curtain and shall be used to secure the 2 halves together. Each curtain is provided with a wall attachment unit, for storage when not in use.

UPPER CURTAIN (NETTING)

The upper section of the curtain is made from mesh woven vinyl and polyester netting, with a 4" wide solid vinyl strip. These 4" wide solid vinyl strips make this curtain extremely durable. Woven mesh material shall have a certificate of flame resistance from the State of California.

LOWER CURTAIN (SOLID)

The lower solid vinyl section of the divider curtain shall extend 10 feet above ground. Vinyl cover shall be 22oz per square yd. vinyl coated polyester with 1000-denier polyester base fabric. Solid vinyl material shall have a certificate of flame resistance from the State of California (Registered fabric No. 140.01). See ACI Color Chart for available colors.